



NOTICE TO CONTRACTORS



January 23, 2015

Wet Niche Inspection

A new inspection code has been added to the required pool inspection template. A "515" Wet Niche inspection will be required to be scheduled and approved to receive a Certificate of Completion for a pool permit. This inspection can be completed in conjunction with "514" Pool Deck Bonding or a separate inspection. This inspection must be completed prior to the pool being filled with water.

This inspection is to verify that the bonding screw for light has been connected and provided with protection to prevent deterioration from the pool water, this is in compliance with 2008 NEC Article 680.23(2)(b).

This inspection will be added to any pool application submitted on or after February 1, 2015.

Jack McStravic
Building Official, City of Marco Island