

## APPENDIX 'B'

### FLORIDA WATER SERVICES CORPORATION WATER TABLE OF DAILY FLOWS FOR VARIOUS OCCUPANCIES

#### Types of Establishments

Apartments.....	250 gpd
Banquet hall (per seat).....	25 gpd
Bars and cocktail lounges.....	5 gpcd (1)
Bathroom (non-residential).....	300 gpd
Beauty shop (per seat).....	170 gpd
Boarding schools (students and staff).....	75 gpd
Boarding houses.....	75 gpcd
Bowling alleys (toilet wastes only, per lane).....	100 gpd (2)
Country clubs, per member.....	25 gpcd
Day schools (with cafeteria, no gymnasium or showers).....	15 gpcd
Day schools (with cafeteria, gymnasiums or showers).....	25 gpcd
Day workers at office and schools.....	20 gpcd
Dentist, per wet chair.....	250 gpd
Drive-in theaters (per car space).....	5 gpd
Factories (with showers).....	30 gpcd
Factories (no showers).....	10 gpd/100 sq. ft.
Funeral home.....	10 gpd/100 sq. ft.
Gas stations (no car wash).....	450 gpd
Hospitals (with laundry) (per bed).....	250 gpd
Hospitals (no laundry) (per bed).....	200 gpd
Hotels and motels (per room & unit).....	125 gpd
Laundromat (per washing machine).....	225 gpcd
Mobile home park (per trailer).....	225 gpd
Movie theaters, auditoriums, churches (per seat).....	3 gpd
Nursing homes.....	150 gpd/100 sq. ft.
Office buildings.....	17 gpd/100 sq. ft.
Public institutions (other than those listed herein).....	75 gpcd
Restaurants (per seat).....	50 gpd
Restaurants (take-out).....	50 gpd/100 sq. ft.
	(350 gpd minimum)
Restaurants (Fast Food) (per seat).....	35 gpd
Single-family residence.....	350 gpd

Townhouse residence .....	280 gpd
Shopping centers .....	17 gpd/100 sq. ft.
Stadiums, frontons, ball parks, etc. (per seat).....	3 gpd
Stores, without kitchen wastes .....	5 gpd/100 sq. ft.
Speculative buildings.....	30 gpd plus 10 gpd/100 sq. ft.
Warehouses .....	30 gpd plus 10 gpd/1,000 sq. ft.

(1) gpcd - Gallons per capita per day

(2) gpd - Gallons per day