

APPENDIX 'A'

1999

FLORIDA WATER SERVICES CORPORATION WASTEWATER TABLE OF DAILY FLOWS FOR VARIOUS OCCUPANCIES

Types of Establishments

Apartments.....	125 gpd
Banquet hall (per seat)	15 gpd
Bars and cocktail lounges	5 gpcd (1)
Bathroom (non-residential).....	250 gpd
Beauty shop (per seat)	150 gpd
Boarding schools (students and staff)	50 gpd
Boarding houses	50 gpcd
Bowling alleys. (toilet wastes only, per lane).....	75 gpd (2)
Country clubs, per member	15 gpcd
Day schools (with cafeteria, no gymnasium or showers).....	8 gpcd
Day schools (with cafeteria, gymnasiums or showers).....	12 gpcd
Day schools (with cafeterias, gymnasiums and showers).....	20 gpcd
Day workers at office and schools.....	15 gpcd
Dentist, per wet chair	200 gpd
Drive-in theaters (per car space)	5 gpd
Factories (with showers)	25 gpcd
Factories (no showers).....	10 gpd/100 sq. ft.
Funeral home	10 gpd/100 sq. ft.
Gas stations (no car wash)	400 gpd
Hospitals (with laundry) (per bed).....	200 gpd
Hospitals (no laundry) (per bed)	150 gpd
Hotels and motels (per room & unit).....	100 gpd
Laundromat (per washing machine)	200 gpcd
Mobile home park (per trailer)	200 gpd
Movie theaters, auditoriums, churches (per seat).....	3 gpd
Nursing homes	125 gpd/100 sq. ft.
Office buildings	10 gpd/100 sq. ft.
Public institutions (other than those listed herein)	75 gpcd
Restaurants (per seat)	35 gpd
Restaurants (take-out).....	35 gpd/100 sq. ft. (350 gpd minimum)
Restaurants (Fast Food) (per seat).....	25 gpd
Single-family residence	200 gpd

Townhouse residence	160 gpd
Shopping centers	10 gpd/100 sq. ft.
Stadiums, frontons, ball parks, etc. (per seat)	3 gpd
Stores, without kitchen wastes	5 gpd/100 sq. ft.
Speculative buildings	10 gpd plus 10 gpd/100 sq. ft.
Warehouses	30 gpd plus 10 gpd/1,000 sq. ft.

- (1) gpcd - Gallons per capita per day
- (2) gpd - Gallons per day